DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DV-6611CS0007
Registration Number
Registriernummer

Field of Application ***Anwendungsbereich***	products of gas and water supply *Produkte der Gas- und Wasserversorgung*
Owner of Certificate ***Zertifikatinhaber***	FRIATEC AG Steinzeugstraße 50, D-68229 Mannheim
Distributor ***Vertreiber***	FRIATEC AG Steinzeugstraße 50, D-68229 Mannheim
Product Category ***Produktart***	gas and water tapping valves : gas and water tapping valve for PE-HD pipework (6611)
Product Description ***Produktbezeichnung***	FRIALEN Pressure Tapping Tee
Model ***Modell***	DAA
Test Reports ***Prüfberichte***	type testing: No. 13927 from 18.01.2017 (BEC) KTW testing: 416.504/2H from 16.12.2015 (ÖFI) hygienic testing: MO 002/14 from 28.05.2014 (TZW) KTW testing: 416.504/4H from 17.02.2016 (ÖFI)
Test Basis ***Prüfgrundlagen***	DVGW W 336-P (01.10.2013) DVGW VP 304 (01.06.2006) DVGW VP 304-B/1 (01.08.2009) DVGW GW 335-B2 (01.09.2004) DVGW GW 335-B2/B1 (01.02.2013) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
Date of Expiry / File No. ***Ablaufdatum / Aktenzeichen***	18.01.2022 / 16-0126-WNE

70028-04-A-DE

24.01.2017 GI A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.

DAkkS
Deutsche Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type ***Typ***	**Technical Data** ***Technische Daten***	**Remarks** ***Bemerkungen***
DAA	pressure rating: water 16 bar; gas 10 bar nominal diameter: 20 mm	electrofusion tapping tee
DAA	pressure rating: water 16 bar; gas 10 bar nominal diameter: 25 mm	electrofusion tapping tee
DAA	pressure rating: water 16 bar; gas 10 bar nominal diameter: 32 mm	electrofusion tapping tee
DAA	pressure rating: water 16 bar; gas 10 bar nominal diameter: 40 mm	electrofusion tapping tee
DAA	pressure rating: water 16 bar; gas 10 bar nominal diameter: 50 mm	electrofusion tapping tee
DAA	pressure rating: water: 16 bar; gas: 10 bar nominal diameter: 63 mm	electrofusion tapping tee

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

diameter of supply piping: 40 up to 225 mm (manufacturing groups: water 14 and 15; gas: 43 and 44)